

Phone: 080-22945350



Email: cewwmwest@bwssb.gov.in

BENGALURU WATER SUPPLY AND SEWERAGE BOARD
Office of the Chief Engineer (Used Water Projects)
6th Floor, Cauvery Bhavan, KG Road, Bangalore - 560009

No. BWSSB/ CE(UWP)/ACE(WWM-VV-W)/DCE(WWM-E&W)/TA-2/78 /2025-26Dt: 23/12/25

CORRIGENDUM/ADDENDUM

Sub: Tender for the Work of providing & laying of 400-1000mm dia sewer lines at missing bits of S4A in various locations of Kethamaranahalli.

Ref: Tender IFT No: BWSSB/CE(WWM-W)/ACE(WWM-VV-W)/DCE(WWM-E&W)/TA-2/1723/2025-26 Dated: 09.12.2025.

~*~*~*~

With reference to the above subject, invitation for the tender was invited vide IFT mentioned in reference letter. This Corrigendum / Addendum indicates the replies to pre bid Queries for the above tender.

Chief Engineer(UWP)
BWSSB

Encl: Replies to the pre bid Queries.

REPLY TO PRE-BID QUERIES FOR Tender for the Work of providing & laying of 400-1000mm dia sewer lines at missing bits of S4A in various locations of Kethamarahalalli .

Tender: BWSSB/CE(WWM-W)/ACE(WWM-VV-W)/DCE(WWM-E&W)/TA-2/1723/2025-26 Dated: 09.12.2025 BWSSB/2025-26/WS/WORK INDENT3016

Sl. No	Document Name	Page No/Section Name	Statement	Query	Submitted on	Reply
1.	Relaxation for Tender conditions	fifth page	Requesting to consider 300mm RCC pipe work done instead of DWC HDPE pipe.	The tender is called up for having work done certificate for DWC HDPE pipe. Hence I am here by requesting you to consider 300mm and above RCC pipe work done instead of DWC HDPE pipe. If considered the opportunity to compete the tender and accomplish the work successfully for freshers and it would be helpful for board.	18-12-2025 10:02:46	Refer Addendum
2	Relaxation for Tender conditions	Tender Documents Page No 5	Requesting for the Relaxation of diameter pipe and pipe to be relaxed to DWC/RCC PIPES	This tenders Technical qualification Criteria has to be relaxed for lower diameter pipes and DWC/RCC PIPES so that competitive price is arrived which shall benefit board and contractors at same time	18-12-2025 10:56:10	Refer Addendum
3	Relaxation for Tender conditions	Tender Documents Page No 5	Requesting to consider 800mm RCC pipe and above and DWC HDPE pipe or RCC NP-3 Pipe	To ensure more competitive bidding and cost efficiency for the Board it is Requested that the technical qualification criteria be relaxed for lower diameter and DWC and RCC pipes This adjustment will expand the bidder pool benefiting both the Board and prospective contractors	18-12-2025 11:08:29	Refer Addendum

ACE(WWM-VV-W)
BWSSB


Chief Engineer(UWP)
BWSSB

Addendum/Corrigendum

1. Tender No: BWSSB/2025-26/WS/Work_INDENT3007
2. Tender No: BWSSB/2025-26/WS/Work_INDENT3016
3. Tender No: BWSSB/2025-26/WS/Work_INDENT3017
4. Tender No: BWSSB/2025-26/WS/Work_INDENT3018
5. Tender No: BWSSB/2025-26/WS/Work_INDENT3019
6. Tender No: BWSSB/2025-26/WS/Work_INDENT3020
7. Tender No: BWSSB/2025-26/WS/Work_INDENT3026

SL.No	Approved PQ Criteria	Relaxation PQ Criteria
1	300mm dia and above DWC HDPE pipe.	300mm dia and above DWC HDPE pipe /RCC NP-3 Class Sewer.
2	400mm dia and above DWC HDPE pipe.	400mm dia and above DWC HDPE pipe / RCC NP-3 Class Sewer.
3	1000 mm dia and above RCC NP-3 class sewer	900 mm dia and above RCC NP-3 class sewer
4	1200 mm dia and above RCC NP-3 class sewer	900 mm dia and above RCC NP-3 class sewer
5	1600 mm dia and above MS Casing pipe through Trenchless Technology	1200 mm dia and above MS Casing pipe through Trenchless Technology


ACE(WWM-H&A.V-W)
BWSSB


ACE(WWM-V.V-W)
BWSSB


CE(UWP)
BWSSB